



Office of the Fire Marshal

Fire Department Connection (FDC) signage requirements

1. All sign locations are to approved by the Fire Official, 8'-0" above grade min. (must be above bushes, autos, dumpsters and containment walls.
2. Weather Proof Construction & paint.
3. Signs to be rectangular in shape, (9" X 15").
4. Letters "FDC" to be 6" high.
5. Letters in words "Fire Department Connection" shall be 2" high.
6. Directional pointing arrows shall be sized to proportionally match letters.
7. Where more than one connection serves the same property; all FDC's shall be grouped together and clearly marked except when approved by the Fire Official.
8. Every FDC shall be at a location acceptable to the fire official.

